H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

Product Configuration Options

OrderCode:	IED-EP+/DAUT/E5-ASZKG_F/D3301311000-A2200000000000-8E

Platform: IED-EP+ EuroProt+ platform	**Type:** DAUT Special automation & control	**Configuration:** E5-ASZKG_F Generator automatic synchronizer in 84HP rack size.

Platform specific options

Position	0	1	2	3	4	5	6	7	8	9	10
Value	D	3	3	0	1	3	1	1	0	0	0

Config specific options

Position	0	1	2	3	4	5	6	7	8	9	10	11	12	13
Value	D	2	2	0	0	0	0	0	0	0	0	0	0	0

Checksum	8E

Detailed platform specific options

Platform version	**Position 0**
Current version	D
Power Supply	**Position 1**
24V	0
48V	1
60V	2
110V	3
220/230V	4
I/O modules	**Position 2**
24V	0
48V	1
60V	2
110V (125V)	3
220V	4
110VAC	5
230VAC	6
Mounting methods	**Position 3**
Rack	0
Flush mounting	1
Wall mounting	2
Semi-flush	3
IP54 rated mounting	4
Wall mounting with terminals	5

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

No mounting	6
Fold-down mounting	7
Fold-down mounting with terminals	8
CPU first communication port	**Position 4**
N/A	0
Fiber optical Ethernet MM/ST	1
Fiber optical Ethernet SM/FC	2
PRP/HSR MM/LC	3
Fiber optical Ethernet MM/LC	4
RJ-45	5
CPU secondary communication port	**Position 5**
N/A	0
Fiber optical Ethernet MM/ST	1
Fiber optical Ethernet SM/FC	2
RJ-45 Ethernet	3
Serial POF	4
Serial Double ring POF	5
Serial glass fiber	6
RS-485/422	7
Fiber optical Ethernet MM/LC	8
Front panel communication port	**Position 6**
RJ-45	1
LCD size	**Position 7**
N/A	0
3.5	1
5.7	2
IEC61850 protocol (additional charge)	**Position 8**
No	0
Yes	1
Customization service (additional charge)	**Position 9**
No	0
Yes	1
Secondary language	**Position 10**
None	0
HUN	1

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

GER	2
RUS	3
ITA(N/A)	4
FRA	5
ROU	6
ESP	7
Detailed config specific options	
Configuration version	**Position 0**
Current version	A
Default binary input module	**Position 1**
N/A	0
O8	1
O12	2
O16	3
O6R5	4
Default binary output module	**Position 2**
N/A	0
R4	1
R8	2
R12	3
R16	4
Binary input module in position F	**Position 3**
N/A	0
O8	1
O12	2
O16	3
Input module in position E	**Position 4**
N/A	0
O8	1
O12	2
O16	3
O9S+BNC	4
O9S+MM/ST	5
Input module in position D	**Position 5**
N/A	0

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

O8	1
O12	2
O16	3
RTD	4
Input module in position C	**Position 6**
N/A	0
O8	1
O12	2
O16	3
RTD	4
AIC	5
Binary output module in position K	**Position 7**
N/A	0
R4	1
R8	2
R12	3
R16	4
Binary output module in position J	**Position 8**
N/A	0
R4	1
R8	2
R12	3
R16	4
I/O module in position I	**Position 9**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
RTD	8
AIC	9
I/O module in position H	**Position 10**

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
RTD	8
AIC	9
O6R5	10
I/O module in position M	**Position 11**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
Number of NC contacts (R8,R12,R16)	**Position 12**
0	0
1	1
2	2
4	3
8	4
Number of 3-Phase voltage detection	**Position 13**
0	0
1	1
2	2
3	3