H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

Product Configuration Options

OrderCode:	IED-EP+/DVEZ/E1-BCU_H/D3301311000-A0000000000-2C

Platform: IED-EP+ EuroProt+ platform	**Type:** DVEZ Bay control	**Configuration:** E1-BCU_H Bay control unit in 42HP rack size. (Numbers of binary I/O in the standard configuration: 0BOut, 0BIn.)

Platform specific options

Position	0	1	2	3	4	5	6	7	8	9	10
Value	D	3	3	0	1	3	1	1	0	0	0

Config specific options

Position	0	1	2	3	4	5	6	7	8	9	10
Value	D	0	0	0	0	0	0	0	0	0	0

Checksum 2C

Detailed platform specific options

Platform version	**Position 0**
Current version	D
Power Supply	**Position 1**
24V	0
48V	1
60V	2
110V	3
220/230V	4
I/O modules	**Position 2**
24V	0
48V	1
60V	2
110V (125V)	3
220V	4
110VAC	5
230VAC	6
Mounting methods	**Position 3**
Rack	0
Flush mounting	1
Wall mounting	2
Semi-flush	3
IP54 rated mounting	4
Wall mounting with terminals	5

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

No mounting	6
Fold-down mounting	7
Fold-down mounting with terminals	8
CPU first communication port	**Position 4**
N/A	0
Fiber optical Ethernet MM/ST	1
Fiber optical Ethernet SM/FC	2
PRP/HSR MM/LC	3
Fiber optical Ethernet MM/LC	4
CPU secondary communication port	**Position 5**
N/A	0
Fiber optical Ethernet MM/ST	1
Fiber optical Ethernet SM/FC	2
RJ-45 Ethernet	3
Serial POF	4
Serial Double ring POF	5
Serial glass fiber	6
RS-485/422	7
Fiber optical Ethernet MM/LC	8
Front panel communication port	**Position 6**
RJ-45	1
RJ-45 remote HMI with 3m cabel	2
LCD size	**Position 7**
N/A	0
3.5	1
5.7	2
IEC61850 protocol (additional charge)	**Position 8**
No	0
Yes	1
Customization service (additional charge)	**Position 9**
No	0
Yes	1
Secondary language	**Position 10**
None	0
HUN	1

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

GER	2
RUS	3
ITA(N/A)	4
FRA	5
ROU	6
ESP	7
Detailed config specific options	
Configuration version	**Position 0**
Current version	A
I/O module in position B	**Position 1**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
I/O module in position C	**Position 2**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
I/O module in position D	**Position 3**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

R16	7
I/O module in position E	**Position 4**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
O9S+BNC	8
O9S+MM/ST	9
ATO	10
AIC	11
I/O module in position F	**Position 5**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
RTD	8
O6R5	9
AIC	10
I/O module in position G	**Position 6**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

I/O module in position H	Position 7
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
RTD	8
AIC	9
O6R5	10
I/O module in position I	**Position 8**
N/A	0
O8	1
O12	2
O16	3
R4	4
R8	5
R12	6
R16	7
Number of NC contacts (R8,R12,R16)	**Position 9**
0	0
1	1
2	2
4	3
8	4
Binary signal transmission	**Position 10**
N/A	0
CPU PB - SM/FC (0-50km)	1
CPU PB - MM/ST (0-2km)	2
3xDir COM - SM/FC (0-50km)	3
3xDir COM - MM/ST (0-2km)	4
G.703	5
CPU PB - SM/FC (10-120km)	6

H-1158 Budapest, Késmárk str. 7/A
Phone: +36 1 415-3800
Fax: +36 1 414-0140
E-mail: protecta@protecta.hu

3xDir COM - SM/FC (10-120km)	7
2xDir COM - SM/FC (0-50km)	8